



FRONT ELEVATION
NOT TO SCALE

NOTES:

- ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.
 - MAXIMUM DESIGN CRITERIA APPLIED
 - REGION C
 - TERRAIN CATEGORY 2
 - DESIGN WIND SPEED 64/ms (ULS)
 - REFER TO STANDARD DRAWING CS-3508 FOR BREAKAWAY JOINT DETAIL.
- POST:**
- SIGN TO BE SUPPORTED BY 2 x 114.3 O.D. x 4.5 CHS (GRADE 250) GALVANISED PIPES.
 - POST SHOULD BE IN CONTACT WITH SIGN SHEETING BRACING OVER THE FULL HEIGHT OF THE SIGN.
 - ALL STEEL POSTS, CONTINUOUS STUBS & COMPONENTS MUST BE HOT DIP GALVANISED.
 - FOR SPOT WELDING OR BOLTING TO BRACING OR ATTACHMENTS APPROVAL TO BE SOUGHT FROM SUPERINTENDENT.
 - ALL WELDS SHALL CONFORM TO AS/NZS 1554-2014 AND BE 6mm CONTINUOUS "SP" FILLET WELDS OR FULL PENETRATION STRUCTURAL PURPOSE UNLESS OTHERWISE NOTED.
 - PLACE 25mm Wide x 50mm Height CLASS 900 YELLOW REFLECTIVE TAPE VERTICALLY FRONT AND BACK ON EACH POST, 750mm ABOVE GROUND LEVEL.
 - UNISTRUT ATTACHMENT SYSTEM TO BE DESIGNED AND SUPPLIED BY SIGN MANUFACTURER BASED ON THE DESIGN WIND SPEED STATED ABOVE.

FOOTING:

- FOOTINGS TO BE 600mm DIA. x 1300mm DEEP (BASED ON 100KPa SOIL BEARING PRESSURE CAPACITY. ENGINEER IS TO BE ADVISED IF SOIL IS LESS THAN 100KPa. THIS MAY BE MODIFIED IN ROCK AS DETERMINED BY ENGINEER.
- POSTS TO BE SET IN N25 CONCRETE.
- FOOTINGS TO BE INSPECTED BY STRUCTURAL ENGINEER PRIOR TO FILL WITH CONCRETE.

SIGN BOARD:

- SIGN BOARD TO BE IN CONTACT WITH AND FIRMLY ATTACHED TO BRACING FOR FULL WIDTH AND FULL HEIGHT OF SIGN BOARD.
- SIGN BOARD TO BE SINGLE SHEET OF MARINE GRADE ALUMINIUM ALLOY DESIGNATION 5052-H38, 3000mm x 1500mm, THICKNESS 1.6mm. ALL CORNERS TO BE ROUNDED AT 155mm RADIUS.
- SIGN FACE TO BE NON-REFLECTIVE MATERIAL.
- BOTTOM EDGE OF SIGN BOARD TO BE MINIMUM 1000mm AND MAXIMUM 1500mm ABOVE NATURAL GROUND LEVEL (AVERAGE CROSS SLOPING SITES).
- USE VERTICAL SETOUT ON CS3450 TO CATER FOR 1500mm HIGH SIGN
- TEXT AND IMAGES TO BE PROVIDED BY THE SUPERINTENDENT BEFORE SIGN IS MANUFACTURED.
- CONTRACTOR TO PROVIDE A PRINT-READY ELECTRONIC FILE SUITABLE FOR SIGN-WRITER PRODUCTION.

SIGN:
NTG FUNDED

FONT:
ARIAL BLACK, ARIAL BOLD, LATO

COLOUR SPECIFICATIONS

NTG OCHRE
PANTONE 159 C
CMYK 0 75 100 2
RGB 203 96 21
HEX # BC5915

SKY BLUE
PANTONE 3005 C
CMYK 100 31 0 2
RGB 18 124 192
HEX # 127CC0

ARAFURA BLUE
PANTONE 2119 C
CMYK 100 100 33 0
RGB 31 31 95
HEX # 1F1F5F

BACK ELEVATION
N.T.S.

No.	DESCRIPTION	DATE	NAME	DEPT./COMPANY
3	AMENDED NOTES	JAN 2022	N.V.	EES/DIPL
2	MODIFIED POST SIZE AND NOTES	JAN 2021	N.V.	EES/DIPL
1	SIGN BOARD TEMPLATE AND SIZE AMENDED	DEC 2019	S.SHI	EES/DIPL
0	ISSUED AS A STANDARD DRAWING	SEPT 2017	J.LEESON	EES/DIPL
AMENDMENTS				

WARNING
BEWARE OF UNDERGROUND SERVICES.
THE LOCATIONS OF UNDERGROUND SERVICES ARE APPROXIMATE ONLY AND THEIR EXACT POSITION SHOULD BE PROVEN ON SITE. NO GUARANTEE IS GIVEN THAT ALL EXISTING SERVICES ARE SHOWN.

DRAWN J.LEESON DATE JULY 2017	CHECKED S.HATZI DATE JULY 2017
DESIGNED	CHECKED
DATE	DATE
DESIGN LEADER S.HATZI DATE 1/09/2017	DESIGN DIRECTOR S.JACKSON DATE 1/09/2017



STANDARD DRAWINGS PROJECT SIGNS				
NTG BRANDING SIGNAGE NTG FUNDED - ROAD AND BUILDINGS				
FILE No.	ASSET No.	SHEET No.	DRAWING No.	AMEND.
-	-	1 OF 1	CS3451	3
				SHEET SIZE A1